

## Infrastructures

### 1. Introduction

Facility management is focused on securing the safety, stability, and reliability of equipment and systems at each experimental facility. It must provide an efficient and effective delivery of support services not only to domestic academia, research institutes, and industry, but also to foreign entities because SPring-8/SACLA offers world-leading, highly brilliant X-rays. We efficiently control and provide 24/7 support to all facilities.

We manage the construction and maintenance of the facilities and their systems, such as electrical equipment, cooling units, experimental drainage, telephones, and hygienic air conditioning, on a five-year plan. This plan includes daily systematic monitoring and periodic inspections. In addition, we have implemented a plan to improve the overall research environment through initiatives to address aging equipment and improve energy savings.

### 2. Management of utilities (lighting, heating, and water)

#### 2-1. Electricity

Electricity is provided by Chubu Electric Power Miraiz Solution's duplicate lines. The receiving voltage is 77 kV. The total contracted power is 31,500 kW. (The industrial power for facilities is 30,000 kW, and the nonindustrial power for administrative/sitting rooms is 1,500 kW.) The electric power consumption in FY2023 was 171 GWh. Figure 1 and Table 1 show the trends of electric power use over the past five years.

For the periods of peak electric power demand, measures are implemented to ensure that the total consumed power remains below the contract limit.

These measures include the increased monitoring of overall use, the adjustment of air-conditioning settings, and the implementation of energy conservation measures.

Additionally, facility management was responsible for supporting researchers' needs and their related organizations and divisions regarding electric power quality/stability enhancements toward upgrading/diversifying research.



Fig. 1. Electricity consumption trends (at the Harima Campus).

Table 1. Electricity consumption.

	FY 2019	FY 2020	FY 2021	FY 2022	FY 2023
Industrial power	195.4	178.6	170.0	169.1	164.3
Nonindustrial power	6.9	7.0	7.3	7.1	6.9
SPring-8 as a whole	202.3	185.6	177.3	176.2	171.2
Comparative (±)	-3.6	-16.7	-8.3	-1.1	-5.0

[Unit: GWh]

#### 2-2. Water and sewage

Tap water from the Chikusa River is provided by the water sewage office, Harima Highlands Wide-area Administration Association. The usage flow rate of tap water in FY2023 was 230 km<sup>3</sup>, while the amount of sewage discharge was 92 km<sup>3</sup>. Figure 2 and Table 2 show the water consumption trends over the past five years, while Figure 3 and Table 3 show the

sewer discharge trends over the past five years.



Fig. 2. Amount of water used (at the Harima Campus).

Table 2. Amount of water used.

	FY 2019	FY 2020	FY 2021	FY 2022	FY 2023
Shared facility	194.6	178.3	156.2	152.4	156.7
RIKEN facility	75.5	76.4	78.3	77.9	73.6
SPring-8 as a whole	270.0	254.7	234.5	230.3	230.3
Comparative (±)	-10.6	-15.3	-20.2	-4.2	0.0

[Unit: km³]




Fig. 3. Amount of sewer discharge (at the Harima Campus).

Table 3. Amount of sewer discharge.

	FY 2019	FY 2020	FY 2021	FY 2022	FY 2023
SPring-8 as a whole	98.4	99.8	87.5	84.4	92.4
Comparative (±)	-11.4	1.4	-12.3	-3.1	8.0

[Unit: km³]

### 2-3. Gas

Town gas (13A) is provided by the West Harima Station of Osaka Gas. The FY2023 usage flow rate was 216 km³. Figure 4 and Table 4 show the trends

of gas use over the past five years.




Fig. 4. Amount of town gas used (at the Harima Campus).

Table 4. Amount of town gas used.

	FY 2019	FY 2020	FY 2021	FY 2022	FY 2023
Shared facility	204.3	216.0	225.4	221.1	201.5
RIKEN facility	15.3	15.5	16.3	15.5	14.6
SPring-8 as a whole	219.6	231.5	241.7	236.6	216.1
Comparative (±)	-22.9	11.9	10.2	-5.1	-20.5

[Unit: km³]

### 2-4. Energy conservation

The following measures were implemented in FY2023 to reduce CO<sub>2</sub> emissions and save energy.

- (1) Packaged air conditioners were updated at the Main Building and Utility Management Building. These efforts eliminated 44 tons of CO<sub>2</sub> per year.
- (2) Heat source equipment was updated at the Experimental Facility for SPring-8 Users. This effort eliminated 53 tons of CO<sub>2</sub> per year.
- (3) All the lighting in the following facilities was updated with LEDs: Main Building, Experimental Facility for SPring-8 Users, Accelerator and Beamline R&D Facility, Machine Laboratory, Medium-length Beamline Facility, RI Laboratory, Storage Ring Annex West, and exterior lights around certain areas of the premises. These efforts eliminated 178 tons

of CO<sub>2</sub> per year.

- (4) The substation equipment was updated at the following facilities: Experimental Facility for SPring-8 Users, Energy Center No. 2, Guest House, and Utility Management Building. These efforts eliminated 13 tons of CO<sub>2</sub> per year.
- (5) Photovoltaic power generation systems were newly installed at the Main Building and Vacuum Drainage Station. These efforts eliminated 34 tons of CO<sub>2</sub> per year.
- (6) The photovoltaic power generation systems at the SACLA Accelerator Building, North Building, and Vacuum Drainage Station generated their own power all year round. These efforts eliminated 18 tons of CO<sub>2</sub> per year.
- (7) Operations of an injection system and a machine cooling system at the Storage Ring were temporarily suspended during inspection adjustment periods in the summer/winter, and at the fiscal year-end. These efforts eliminated 1,704 tons of CO<sub>2</sub> per year.
- (8) The machine cooling equipment, which was a recirculating piped water system used to remove waste heat at the Storage Ring, was upgraded to a more energy-efficient one. The new equipment uses cold outside air in the winter and a refrigerating machine in the summer. These efforts eliminated 162 tons of CO<sub>2</sub> per year.
- (9) The partial operation of the air handling units (AHUs) in the Experimental Hall at the Storage Ring during the summer/winter maintenance periods and at the fiscal year-end eliminated 623 tons of CO<sub>2</sub> per year.
- (10) The partial operation of outdoor AHUs and air-exhaust ventilators of the tunnels for the injector and accelerator at the Storage Ring during the summer/winter maintenance periods and at the

fiscal year-end eliminated 42 tons of CO<sub>2</sub> per year.

- (11) The partial operation of air conditioners in the Experimental Hall at the RI Laboratory during the summer/winter maintenance periods and at the fiscal year-end eliminated 20 tons of CO<sub>2</sub> per year.
- (12) The partial operation of the fan coil units (FCUs) in the tunnels for the injector and accelerator at the Storage Ring during the summer/winter maintenance periods and the fiscal year-end eliminated 20 tons of CO<sub>2</sub> per year.
- (13) The partial operation of the humidifying function of the outdoor air handling units (OHUs) in the tunnels for the injector/accelerator and in the Experimental Hall at the Storage Ring eliminated 66 tons of CO<sub>2</sub> per year.
- (14) The use of air-conditioning units during the night was suspended between 19:00 and 07:00 at the research building of the Medium-length Beamline Facility.

### **3. Environmental conservation**

#### **3-1. Industrial waste**

Wastes discharged from operating activities were mainly experimental equipment, office automation equipment, scrap metal, waste plastics such as packing material/filters, and sludge generated during water treatment. Wastes containing poisonous and deleterious substances, such as experimental waste liquid and lead-acid batteries, used in operations and maintenance were collected and stored as specially controlled industrial waste. Additionally, because tools such as sterilized syringe needles and scalpels are difficult to

distinguish from medical waste, they were collected and stored as specially controlled industrial waste. Then, we hired a contracted waste management company to dispose of them.

Although animals used in laboratory experiments can be disposed of as general waste, we buried them in an animal cemetery to express our sympathy for the loss of the laboratory animals,

following the guidance of the local municipality.

Because cooperation from employees and users is necessary to properly conduct garbage separation, explanatory sessions on waste disposal were held and warning notices were issued via emails and posted announcements to employees not properly handling waste. Tables 5–7 show the amounts of waste generated over the past five years.

Table 5. Waste types and amounts in industrial waste.

	FY 2019	FY 2020	FY 2021	FY 2022	FY 2023
Sludge	2,337	4,405	2,165	3,273	1,339
Waste oil/slush	7,892	3,560	5,024	1,999	2,801
Waste alkali	123	44	90	485	26
Waste acid	81	92	14	57	447
Waste plastic	11,141	8,898	9,454	8,733	9,000
Waste wood	2,886	1,949	1,653	1,674	6,075
Waste/scrap metal	93,505	60,779	113,255	65,443	136,146
Waste/cullet glass	710	628	511	403	906
Wastes other than above (concrete, stone, etc.)	75	44	925	810	11
Biochemically stable waste mixture	9,560	2,797	3,156	1,980	19,536
Biochemically unstable waste mixture	8,376	3,062	4,458	2,823	9,235
Waste plastic (containing asbestos)	0	0	0	0	0
Mercury-containing product industrial waste	1,074	710	711	1,035	570
Dry batteries	301	210	50	30	60

[Unit: kg]

Table 6. Amount of specially controlled industrial waste.

	FY 2019	FY 2020	FY 2021	FY 2022	FY 2023
Waste acid	2,694	489	250	375	561
Waste alkali	428	430	475	49	54
Waste oil	237	305	187	50	22
Sludge	134	93	174	14	19
Infectious waste	7	10	10	10	10
PCB	—	—	—	—	—

[Unit: kg]

Table 7. Amount of general waste.

	FY 2019	FY 2020	FY 2021	FY 2022	FY 2023
Laboratory animals	444	36	158	214	202

[Unit: kg]

Harima Administrative Division, RIKEN

Harima Safety Center, RIKEN